



- 3" COMPACTED DEPTH CLASS B ASPHALT CONCRETE
- 2" COMPACTED DEPTH CRUSHED SURFACING TOP COURSE
- 6" CLASS B COMPACTED DEPTH GRAVEL BASE COURSE
- VERTICAL CURBING ONLY (SEE CURBING DETAIL ST-6 FOR DIMENSIONS)

SIEVE SIZE	PERCENT PASSING	
	BASE COURSE	TOP COURSE
1-1/4" SQUARE	100	
3/4" SQUARE		100
5/8" SQUARE	50-80	
1/4" SQUARE	30-50	55-75
U.S. NO. 40	3-18	8-24
US.S NO. 200	7.5 MAX	10.0 MAX
% FRACTURE	75 MIN.	75 MIN.
SAND EQUIVALENT	35 MIN.	35 MIN.

**NOTES:**

1. ALL WORKMANSHIP INSTALLATION METHODS AND MATERIALS SHALL BE IN ACCORDANCE WITH THE CITY OF OAK HARBOR STANDARDS AND THE MOST RECENT COPY OF THE STATE OF WASHINGTON STANDARD SPECIFICATIONS FOR ROAD, BRIDGE, AND MUNICIPAL CONSTRUCTION (WSDOT/APWA).



**City of  
Oak Harbor**  
ENGINEERING DEPARTMENT  
865 SE Barrington Drive  
Oak Harbor, WA 98277

**MINOR ARTERIAL, 2 LANE  
WITH TWO-WAY  
LEFT TURN LANE OR MEDIAN**

STREET DETAILS\_5-24-17.DWG