



3" COMPACTED DEPTH CLASS B ASPHALT CONCRETE  
 2" COMPACTED DEPTH CRUSHED SURFACING TOP COURSE  
 6" CLASS B COMPACTED DEPTH GRAVEL BASE COURSE

SIEVE SIZE	PERCENT PASSING	
	BASE COURSE	TOP COURSE
1-1/4" SQUARE	100	
3/4" SQUARE		100
5/8" SQUARE	50-80	
1/4" SQUARE	30-50	55-75
U.S. NO. 40	3-18	8-24
U.S. NO. 200	7.5 MAX	10.0 MAX
% FRACTURE	75 MIN.	75 MIN.
SAND EQUIVALENT	35 MIN.	35 MIN.

**NOTES:**

1. ALL WORKMANSHIP INSTALLATION METHODS AND MATERIALS SHALL BE IN ACCORDANCE WITH THE CITY OF OAK HARBOR STANDARDS AND THE MOST RECENT COPY OF THE STATE OF WASHINGTON STANDARD SPECIFICATIONS FOR ROAD, BRIDGE, AND MUNICIPAL CONSTRUCTION (WSDOT/APWA).



*City of  
Oak Harbor*  
 ENGINEERING DEPARTMENT  
 865 SE Barrington Drive  
 Oak Harbor, WA 98277

**MINOR ARTERIAL  
INDUSTRIAL  
ENTERPRISE AREA**

STREET DETAILS\_5-24-17.DWG